



**Fire House Building Committee
Special Meeting**

Minutes: Thursday, April 25, 2024

Meeting was held at the Norfolk Town Hall

Meeting was called to order at 6:05 PM

Those in attendance: Matt Ludwig, Jeff Torrant, Lou Barbagallo, Mark Morgan, Ron Zanobi, Matt Riiska
Others in attendance: Paul Padua, Tony Kiser, Steve Hutchins, Barry Roseman, Tobin DeShazo
For Silver-Petrucci: David Stein, James Nall

Review of Project

Exterior Design Feature

Took design consideration from previous meeting making the windows in the meeting area small and not having them extend to the ground.

Siding Material: Hardie Board (red on apparatus portion of the building & black on meeting room portion & Stone Veneer

Roofing Material: Standing Seam

Windows: Aluminum w/tinted glass

Apparatus Doors: Four-Fold – Concern noted for the amount of glass for security and “R” value. Doors can be serviced by Overhead Door of Torrington

All other doors – Standard

Generator placed on west side of building – diesel

- Need to make sure tank can be filled easily in all types of weather.

Parking Area: Need to have thru path in the front parking area to aid in snow removal.

Pervious pavers?

Interior Design Feature

Move stairs to the mezzanine to provide more wall space on the ground floor and more accessibility to mezzanine.

Change northwest corner of interior design to allow for exterior door access.

Meeting room area: Combine (2) offices to create a conference room. Office for the chief will remain.

Review of Material Spec Sheets provided by S-P on April 24, 2024 in email with renderings.

MR will contact ZEO to discuss the location of the transformer

Next Meeting: Thursday, May 30, 2024, 6:00 PM at the Norfolk Town Hall

With no further business, the meeting was adjourned at 8:05 PM.

Respectfully Submitted:

Matt Riiska

Acting Secretary